

Technical-economic study of a PV solar-hydrogen system with cogeneration for re-electrification in hotels

Authors

- Laince Pierre MOULEBE
- *Abdelwahed TOUATI*
- *Eric OBAR AKPOVIRORO*
- *Nabila RABBAH*



Laboratory of Structural Engineering, Intelligent Systems & Electrical Energy
ENSAM, Casablanca, Hassan II University, Morocco

The 5th TECHNIUM International Conference
July 18, 2020

ENERGY BALANCE OF THE BUILDING STUDIED

The hotel's Heating Ventilation and Air Conditioning (HVAC)

a) HVAC consumption

Description	Consumption (KWh/year)
Heating pump	20000
Electric heater	20000
air conditioner	50400
Air renewal	162000
Kitchen extractor	5600
Hot water	61000
Hot water	372000

b) Expenditure in 10 years

FE(gCO2e/KWh)	Pc(€/year)	Energy cost (€/year)	Cost (€/10 years)	
49	98	4318	707170.6	
49	98	4318		
59	297.36	10881.36		
59	955.8	34975.5		
75	42	1209.04		
58	353.8	13169.9		
443	16479.6	25854		423336


ENERGY BALANCE OF THE BUILDING STUDIED

Solar dimensioning for supplying electrical consumers

Principaux paramètres système		Type de système		Système isolé avec batteries	
Orientation plan capteurs		inclinaison	32°	azimut	0°
Modules PV		GG1H-300 Bifacial PERC 60 cells - Double Glass	Pnom	300 Wc	
Champ PV		Nombre de modules	726	Pnom total	218 kWc
Batterie		Modèle	3 TU 6E Plus	Technologie	Pb-acide, ouverte, tubulai
Pack de batteries		Nombre d'unités	1480	Tension / Capacité	240 V / 16650 Ah
Besoins de l'utilisateur		Charge constante fixée	35.3 kW	Global	309 MWh/an
Principaux résultats de la simulation					
Production du système	Energie disponible	386551 kWh/an	Productible	1775 kWh/kWc/an	
	Energie utilisée	306582 kWh/an	En excès (inutilisée)	66492 kWh/an	
	Indice de performance (PR)	67.26 %	Fraction solaire (SF)	99.12 %	
Besoins non satisfaits	Fraction du temps	0.9 %	Energie manquante	2720 kWh/an	
Vieillessement batterie (Etat d'usure (SOW))	SOW cyclage	96.0%	SOW statique	90.0%	

ENERGY BALANCE OF THE BUILDING STUDIED


Mathematical modeling of the Hydrogen to simulate the power to be supplied by the PEM electrolysis system



RESULTS AND CONCLUSION

Description	Energy cost (Kwh/year)	System cost (€)
Energy H ₂ PEM	210240	5 247 240
Energy PV	1918440	284700

- Case1: A return on investment in 3 years spending 55% less over 10 years.
- Case2 : For the second case, the return on investment is done in 5 years and we spend 33% less over 10 years.
- As a result, the solar panel solution with hydrogen storage coupled with a cogeneration system is a more profitable solution in the medium term for the residential-tertiary sector than the combination of electricity-natural gas or 100% electricity.



**THANK YOU FOR
YOUR
ATTENTION**

